K-T-STUECKE 130 RD IG

Tees 130, reducing, female/female/female

HANSA-FLEX

Omadused

Pealispind	Hot dip galvanised
Temperatuuri ulatus	-20 °C to +300 °C (at 20 bar)
Ühenduskeere	acc. ISO 7-1
Materjal	Black malleable iron B350-10, design symbol A
Luba	DIN DVGW



Vihje

Lisaandmed saate soovi korral.

Kirjeldus

Acc. to DIN EN 10242 (formerly DIN 2950). The classic - and the most popular - screw fitting series for pipe construction. These fittings are characterized by their high mechanical strength and surface quality to DIN 2444. They are completely coated with a layer of pure zinc and are therefore suitable for drinking water. They are also protected against rust. The fittings are used in pipe construction, plumbing and gas installations as well as a wide range of industrial applications.

Tellimisinfo

Attention: the thread sizes of Article K-07403783 have changed.

Lisateave

Further types and dimensions on request.

Artikkel

Märgistus	Keere 1	Vähendatud T-haru keere 2	Keere 3
K- 07 40 37 97	Rp 3/8	Rp 1/4	Rp 3/8
K- 07 40 37 83	Rp 1/2	Rp 1/4	Rp 1/2
K- 07 40 37 84	Rp 1/2	Rp 3/8	Rp 1/2
K- 07 40 37 94	Rp 3/4	Rp 1/4	Rp 3/4
K- 07 40 37 95	Rp 3/4	Rp 3/8	Rp 3/4
K- 07 40 37 93	Rp 3/4	Rp 1/2	Rp 3/4
K- 07 40 37 71	Rp 1	Rp 3/8	Rp 1
K- 07 40 37 69	Rp 1	Rp 1/2	Rp 1
K- 07 40 37 70	Rp 1	Rp 3/4	Rp 1
K- 07 40 37 81	Rp 1 1/4	Rp 3/8	Rp 1 1/4
K- 07 40 37 79	Rp 1 1/4	Rp 1/2	Rp 1 1/4
K- 07 40 37 80	Rp 1 1/4	Rp 3/4	Rp 1 1/4
K- 07 40 37 78	Rp 1 1/4	Rp 1	Rp 1 1/4
K- 07 40 37 76	Rp 1 1/2	Rp 3/8	Rp 1 1/2
K- 07 40 37 74	Rp 1 1/2	Rp 1/2	Rp 1 1/2
K- 07 40 37 75	Rp 1 1/2	Rp 3/4	Rp 1 1/2
K- 07 40 37 73	Rp 1 1/2	Rp 1	Rp 1 1/2
K- 07 40 37 98	Rp 1 1/2	Rp 1 1/4	Rp 1 1/2
K- 07 40 37 90	Rp 2	Rp 1/2	Rp 2
K- 07 40 37 91	Rp 2	Rp 3/4	Rp 2
K- 07 40 37 87	Rp 2	Rp 1	Rp 2
K- 07 40 37 89	Rp 2	Rp 1 1/4	Rp 2
K- 07 40 37 88	Rp 2	Rp 1 1/2	Rp 2
K- 07 40 52 02	Rp 2 1/2	Rp 1	Rp 2 1/2
K- 07 40 52 19	Rp 2 1/2	Rp 1 1/4	Rp 2 1/2
K- 07 40 52 03	Rp 2 1/2	Rp 2	Rp 2 1/2
K- 07 40 52 18	Rp 2 1/2	Rp 1 1/2	Rp 2 1/2
K- 07 40 52 05	Rp 3	Rp 2	Rp 3
K- 07 40 52 06	Rp 3	Rp 2 1/2	Rp 3

Vaatamata põhjalikule kontrollile ei saa me vigade esinemist välistada ning ei vastuta olemasolevate andmete eest.